

Tulare Local Healthcare District dba Tulare Regional Medical Center

Agenda Item

Board Meeting Date: December 15, 2021

Title to Appear on Agenda: Arc Flash Risk Survey

Brief Description:

Since 2002, Section 110 of the National Electric Code has required that arc flash warning labels be installed on all control panels, motor control cabinets, panelboards, and switchboards. The arc flash survey is how the hospital gets the data for the labels. It has to cover the entire electrical distribution system of the hospital.

Background and Details:

Adventist Health Facilities Manager sought proposals from three vendors at prevailing wage rates, only receiving two (2) proposals, as follows:

Allied Reliability Group	\$34,995 + \$8,500 for Site Specific Safety Training
Brady Safety	\$46,450 + additional fee for safety training, cost not specified
Howe Electric	No response

Recommended Action:

Approve Bid Proposal from Allied Reliability Group in the amount of \$34,995 + \$8,500 for safety training totaling \$43,495.

Exhibits:

Attached – Proposal from Allied Reliability Group