

## **Tulare Local Healthcare District dba Tulare Regional Medical Center**

### **Agenda Item**

**Board Meeting Date:** 08-16-18

**Title to Appear on Agenda:** Rental Chiller installation

**Brief Description:** Rental Chiller installation subject to OSHPD requirement mandates

**Background and Details:** The Emergency chiller which was rejected by OSHPD and are requiring the vendor to install chilled water piping and the electrical as if it was a complete installation. The monies associated with this upfront cost will be dampened on the back end as the piping will be permanent and will not necessitate additional cost for the permanent one once installed. This project CANNOT proceed forward without these revisions implemented.

All of the items listed are specific to life safety, NFPA 99 and or Title 22. The repairs will require OSHPD approval.

**Exhibits:** See attached

**Recommended Action:** Hospital Board approve New England Sheet Metal and Mechanical Co. to proceed with proposed scope of work delineated in proposal.

